



**2016 Annual Consumer Confidence Report Mailing Certification**  
**(Required for Community Water Systems Serving  $\geq 10,000$  People)**

**Public Water System Name:** Bradshaw Mountain View Water

**Public Water System Number:** 13062

As outlined in Title 40, Code of Federal Regulations (CFR) § 141.155, as incorporated by reference in the Arizona Administrative Code R18-4-117, the Public Water System (PWS) named above hereby confirms that its Consumer Confidence Report (CCR) has been distributed to its customers. The PWS also certifies that the information contained in the CCR is correct and consistent with the compliance monitoring data previously submitted to the Arizona Department of Environmental Quality.

**All community water systems must mail or otherwise direct deliver one copy of the report to each customer (defined as billing units or service connections), except for systems serving  $< 10,000$  people that may opt to meet the requirements via the State of Arizona's CCR Waiver instead (see CCR Waiver Form).**

**CCR DISTRIBUTION DIRECT DELIVERY METHODS** (Please check all that apply):

☒ CCR was distributed by mail.

☐ CCR was distributed by other direct delivery method. Specify direct delivery methods:

☐ Mail – notification that CCR is available on Web site via a direct uniform resource locator (URL)

☐ E-mail – direct URL to CCR

☐ E-mail – CCR sent as an attachment to the e-mail

☐ E-mail – CCR sent embedded in the e-mail

☐ Other: \_\_\_\_\_

If the CCR was provided electronically, please describe how a customer requests paper CCR delivery: \_\_\_\_\_

If the CCR was provided by a direct URL, please provide the direct URL Internet address:

www. \_\_\_\_\_



2016 **Annual Consumer Confidence Report Mailing Certification**  
**(CONTINUED)**

**Public Water System Name:** Bradshaw Mountain View Water

**Public Water System Number:** 13062

☒ **"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods as recommended by the state/primacy agency:**

☒ posting the CCR on the Internet at:

www. sumwater.com

☐ mailing the CCR to postal patrons within the service area (attach list of zip codes used)

☐ advertising availability of the CCR in news media (attach copy of announcement)

☐ publication of CCR in local newspaper (attach copy of newspaper announcement)

☐ posting the CCR in public places (attach a list of locations)

☐ delivery of multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers

☐ delivery to community organizations (attach a list)

☐ electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)

☐ electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)

☐ Delivered CCR to other agencies as required by the state/primacy agency (attach a list)

**Additional Requirements for CWS Serving  $\geq$  100,000 people:**

☒ Posted CCR on a publicly-accessible Internet site at:

www. sumwater.com

**Certified by:**

Name & Signature: STUART MCLEAN

Title: GENERAL MANAGER

Phone #: 928 3005764

Date: 5/17/17





## Consumer Confidence Report For Calendar Year 2016

Este informe contiene información muy importante sobre el agua usted bebe.  
Tradúscalo ó hable con alguien que lo entienda bien.

### I. Public Water System (PWS) Information

PWS ID Number	PWS Name		
AZ04 -13062	Bradshaw Mountain View Water		
Contact Person and Title		Phone Number	E-Mail Address
Stuart McLean		(800) 315-5333	info@southwesternutility.com

We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact Bradshaw Mountain View Water at (800) 315-5333 for additional opportunity and meeting dates and times.

### II. Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source(s): Aqua Fria Basin

### III. Drinking Water Contaminants

Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban stormwater runoff, and septic systems.

Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

### IV. Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the



U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

## V. Source Water Assessment

*Based on the information currently available on the hydrogeologic settings of and the adjacent land uses that are in the specified proximity of the drinking water sources of this public water system, the department has given a low risk designation for the degree to which this public water system's drinking water sources are protected. A low risk designation indicates that most source water protection measures are either already implemented, or the hydrogeology is such that the source water protection measures will have little impact on protection.*

Further source water assessment documentation can be obtained by contacting ADEQ, 602-771-4641.

## VI. Definitions

AL = Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements.

MCL = Maximum Contaminant Level – The highest level of a contaminant that is allowed in drinking water.

MCLG = Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health.

MFL = Million fibers per liter.

MRDL = Maximum Residual Disinfectant Level. The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap.

MRDLG = Maximum Residual Disinfectant Level Goal. The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur.

MREM = Millirems per year – a measure of radiation absorbed by the body.

NA = Not Applicable, sampling was not completed by regulation or was not required.

NTU = Nephelometric Turbidity Units, a measure of water clarity.

PCi/L = Picocuries per liter - picocuries per liter is a measure of the radioactivity in water.

PPM = Parts per million or Milligrams per liter (mg/L).

PPB = Parts per billion or Micrograms per liter (µg/L).

PPT = Parts per trillion or Nanograms per liter.

PPQ = Parts per quadrillion or Picograms per liter.

TT = Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water.

ppm x 1000 = ppb
------------------

ppb x 1000 = ppt
------------------

ppt x 1000 = ppq
------------------

## VII. Health Effects Language

**Nitrate** in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. "High nitrate levels in drinking water can cause blue baby syndrome." Nitrate levels may rise quickly for short periods-of-time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

If **arsenic** is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.



**LEAD:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **Bradshaw Mountain View Water** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## VII. Water Quality Data

Microbiological	Violation Y or N	Number of Samples Present <b>OR</b> Highest Level Detected	Absent (A) or Present (P) <b>OR</b> Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Total Coliform Bacteria</b> (System takes ≥ 40 monthly samples) 5% of monthly samples are positive; (System takes ≤ 40 monthly samples) 1 positive monthly sample	N		A	0	0	2 monthly	Naturally Present in Environment
Disinfectants	Violation Y or N	Running Annual Average (RAA)	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Chlorine (ppm)</b>	N	0.7	0.3 - 1	MRDL = 4	MRDLG = 4	2 monthly	Water additive used to control microbes
Disinfection By-Products	Violation Y or N	Running Annual Average (RAA) <b>OR</b> Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Haloacetic Acids (ppb) (HAA5)</b>	N	4.5	<2 – 4.5	60	n/a	8/2016	Byproduct of drinking water disinfection
<b>Total Trihalomethanes (ppb) (TTHM)</b>	N	37.2	2.5 – 37.2	80	n/a	8/2016	Byproduct of drinking water disinfection
Lead & Copper	Violation Y or N	90 <sup>th</sup> Percentile <b>AND</b> Number of Samples Over the AL	Range of All Samples (L-H)	AL	ALG	Sample Month & Year	Likely Source of Contamination
<b>Copper (ppm)</b>	N	0.086	<0.01 – 0.095	AL = 1.3	ALG = 1.3	6/2016	Corrosion of household plumbing systems; erosion of natural deposits
<b>Lead (ppb)</b>	N	9.3	<1 – 12	AL = 15	0	6/2016	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	Violation Y or N	Running Annual Average (RAA) <b>OR</b> Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Alpha emitters (pCi/L) (this is Gross Alpha 4002)</b>	N	2	EPDS001 2 EPDS002 1.1 EPDS003 1.3 EPDS004 1.4 EPDS005 1.9	15	0	4/2013 3/2016 9/2016 4/2013	Erosion of natural deposits

Inorganic Chemicals (IOC)	Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Arsenic (ppb)	N	4.8	EPDS001 4.8 EPDS002 3 EPDS003 2.7 EPDS004 2.1 EPDS005 4.2	10	0	3/2016 9/2016	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Barium (ppm)	N	0.016	EPDS001 0.005 EPDS002 0.016 EPDS003 0.007 EPDS004 0.014 EPDS005 0.003	2	2	3/2016 9/2016	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	N	3.2	EPDS001 3.2 EPDS002 1.3 EPDS005 2	100	100	9/2016 4/2013 4/2013	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	N	0.29	EPDS001 0.22 EPDS002 0.25 EPDS003 0.21 EPDS004 0.24 EPDS005 0.29	4	4	3/2016 9/2016	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (ppm)	N	6.3	EPDS001 3.6 EPDS002 6.3 EPDS003 2.5 EPDS004 3.2 EPDS005 3.2	10	10	3/2016 9/2016	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (ppm)	N	54	EPDS001 38 EPDS002 29 EPDS003 31 EPDS004 37 EPDS005 54	N/A	N/A	3/2016 9/2016	N/A