			r Year 2023 uien que lo entienda bien. Tradúscalo ó hable con alguien					
que lo entienda bien.								
Public Water System ID Number AZ0410264	Public Water System Name Thim Water Company 2							
Contact Name and Title	- mini Water e	Phone Number	E-mail Address					
Jason Long		520-431-7723	jason@longwatermgt.com					
			like to learn more about public participation or -431-7723 for additional opportunity and					
Drinking Water Sources								
water travels over the surface of the land radioactive material, and can pickup sub In order to ensure that tap water is safe	d or through the estances resulting to drink, EPA pre and Drug Admin	ground, it dissolves naturally g from the presence of anima escribes regulations which lir istration (FDA) regulations e						
Drinking Water Contaminants								
Microbial Contaminants: Viruses and bacter from sewage treatment plants, septic system livestock operations, and wildlife	,	come from a	Pesticides and Herbicides : Synthetic organic compounds that come from agriculture, urban storm water runoff, and a wide variety of residential uses					
Disinfectants and Disinfection By-product used to control microbes, and the by-product between disinfectants and natural organic ma	s of interactions	chemical by- petroleum pr	Organic Chemical Contaminants : Synthetic and volatile organic chemical by-products that come from industrial processes, petroleum production, gas stations, urban storm water runoff, and septic systems.					
Inorganic Contaminants : Salts, metals, and other inorganic contaminants that can occur naturally or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming			Radioactive Contaminants : Can be naturally occurring or be the result of oil and gas production and mining activities.					
Vulnerable Population								
	essarily indicate	that water poses a health ris	st small amounts of some contaminants. The k. Some people may be more vulnerable to					
	ner immune syste	em disorders, some elderly, a	py, persons who have undergone organ and infants can be particularly at risk from are providers.					

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

Source Water Assessment

Based on the information currently available on the hydrogeologic settings of and the adjacent land uses that are in the specified proximity of the drinking water source(s) of this public water system, the department has given a low risk designation for the degree to which this public water system drinking water source(s) are protected. A low risk designation indicates that most source water protection measures are either already implemented, or the hydrogeology is such that the source water protection measures will have little impact on protection.

Further source water assessment documentation can be obtained by contacting ADEQ.

Definitions

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present

Level 2 Assessment: A very detailed study of the water system to identify potential problems contributing to an *E. coli* MCL violation, and/or why total coliform bacteria was present

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water

Maximum Contaminant Level Goal MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health

Maximum Residual Disinfectant Level (MRDL): The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap

Maximum Residual Disinfectant Level Goal (MRDLG): The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur

Minimum Reporting Limit (MRL): The smallest measured concentration of a substance that can be reliably measured by a given analytical method

Millirems per year (MREM): A measure of radiation absorbed by the body

Not Applicable (NA): Sampling was not completed by regulation or was not required

Not Detected (ND or <): Not detected by the sampling laboratory above a minimum level of detection

Nephelometric Turbidity Units (NTU): Measure of water clarity for drinking water systems using surface water as source water

Million fibers per liter (MFL): Measure of asbestos contamination

Picocuries per liter (pCi/L): Measure of the radioactivity in water

Unit Coversions:

ppm: Parts per million or Milligrams per liter (mg/L) ppm x 1000 = ppb

ppb: Parts per billion or Micrograms per liter (µg/L) ppb x 1000 = ppt

ppt: Parts per trillion or Nanograms per liter (ng/L) ppt x 1000 = ppq

ppq: Parts per quadrillion or Picograms per liter (pg/L)

Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Thim Water Company 2 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Water Quality Data – Regulated Contaminants

As authorized and approved by EPA, the state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of our data, though representative, is more than one year old.

Disinfectants	MCL Violation Y or N	Average	Range	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	Ν	0.29	0.08 to 0.98	4	4	2023	Water additive used to control microbes
Disinfection By-Products	MCL Violation Y or N	Highest Location Average or Highest Level Detected	Range Low-High	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Total Trihalomethanes (TTHM) (ppb)	N	11.2	0 to 11.2	80	N/A	8 / 2023	Byproduct of drinking water disinfection
Lead & Copper	AL Violation?	90 th Percentile	Number of Samples Exceeding the AL	AL	ALG	Sample Month / Year	Likely Source of Contamination
Copper (ppm)	Ν	0.02	0	1.3	1.3	9 / 2021	Corrosion of household plumbing systems; erosion of natural deposits
Inorganic Chemicals (IOC)	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Nitrate ² (ppm)	N	2.1	2.1 to 2.1	10	10	2 / 2023	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (ppm)	N	49	49 to 49	N/A	N/A	8 / 2021	Erosion of natural deposits

Water Quality Table - ADEQ PFAS Monitoring

Your drinking water was sampled for the presence and concentration of 29 different per- and polyfluoroalkyl substances, some known by the acronyms PFAS, PFOA, PFNA, PFHxS, PFBS, and GenX, a group of contaminants in the final stages of becoming regulated by the EPA. PFAS are man-made chemicals that are resistant to heat, water, and oil. They have been used since the 1940s to manufacture various consumer products, including fire-fighting foam and stain resistant, water-resistant, and nonstick items. Many PFAS do not break down easily and can build up in people, animals, and the environment over time. Scientific studies have shown that exposure to certain PFAS can be harmful to people and animals, depending on the level and duration of exposure.

To learn more about this group of chemicals, we encourage you to read the ADEQ-provided "PFAS 101 Fact Sheet" and to visit the ADEQ website at https://www.azdeq.gov/pfas-resources

* EPA is proposing a Hazard Index MCL to limit any mixture containing one or more of PFNA, PFHxS, PFBS, and/or GenX Chemicals. The Hazard Index considers the different toxicities of PFNA, GenX Chemicals, PFHxS, and PFBS. For these PFAS, water systems would use a hazard index calculation to determine if the combined levels of these PFAS in the drinking water at that system pose a potential risk and require action (Source: EPA Fact Sheet: Understanding the PFAS National Primary Drinking Water Proposal Hazard Index).

No PFAS Contaminants were detected in your water.