



## Consumer Confidence Report for Calendar Year 2020

Este informe contiene información muy importante sobre el agua usted bebe.  
Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number	Public Water System Name		
AZ0411334	Sunland Water Company		
Contact Name and Title	Phone Number	E-mail Address	
Elle Morano, Compliance Manager	602-795-8276	compliance@southwesternutility.com	
<p>We want our valued customers to be informed about their water quality. If you would like to learn more, please contact Jason Long at 520-431-7723.</p>			

### Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**Our water source(s):** Two wells that withdraw groundwater from the Santa Cruz River Watershed.

### Drinking Water Contaminants

**Microbial Contaminants:** Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

**Organic Chemical Contaminants:** Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

**Inorganic Contaminants:** Such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

**Radioactive Contaminants:** That can be naturally occurring or be the result of oil and gas production and mining activities.

**Pesticides and Herbicides:** Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

### Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

### Source Water Assessment

Based on the information currently available on the hydrogeological settings of and the adjacent land uses that are in the specified proximity of the drinking water source(s) of this PWS, the department has given a low risk designation for the degree to which this PWS drinking water source(s) are protected. A low risk designation indicates that most source water protection measures are either already implemented, or the hydrogeology is such that the source water protection measure will have little impact on protection.

Further source water assessment documentation can be obtained by contacting ADEQ.

**Definitions**

<b>Treatment Technique (TT):</b> A required process intended to reduce the level of a contaminant in drinking water	<b>Minimum Reporting Limit (MRL):</b> The smallest measured concentration of a substance that can be reliably measured by a given analytical method
<b>Level 1 Assessment:</b> A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present	<b>Millirems per year (MREM):</b> A measure of radiation absorbed by the body
<b>Level 2 Assessment:</b> A very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria was present	<b>Not Applicable (NA):</b> Sampling was not completed by regulation or was not required
<b>Action Level (AL):</b> The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements	<b>Not Detected (ND or &lt;):</b> Not detectable at reporting limit
<b>Maximum Contaminant Level (MCL):</b> The highest level of a contaminant that is allowed in drinking water	<b>Nephelometric Turbidity Units (NTU):</b> A measure of water clarity
<b>Maximum Contaminant Level Goal (MCLG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health	<b>Million fibers per liter (MFL)</b>
<b>Maximum Residual Disinfectant Level (MRDL):</b> The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap	<b>Picocuries per liter (pCi/L):</b> Measure of the radioactivity in water
<b>Maximum Residual Disinfectant Level Goal (MRDLG):</b> The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur	<b>ppm:</b> Parts per million or Milligrams per liter (mg/L)
	<b>ppb:</b> Parts per billion or Micrograms per liter (µg/L)
	<b>ppt:</b> Parts per trillion or Nanograms per liter (ng/L) <span style="float: right;">ppm x 1000 = ppb</span>
	<b>ppq:</b> Parts per quadrillion or Picograms per liter (pg/L) <span style="float: right;">ppb x 1000 = ppt</span>
	<span style="float: right;">ppt x 1000 = ppq</span>

**Lead Informational Statement:**

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Sunland Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

**Water Quality Data – Regulated Contaminants**

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination	
E. Coli	N	0	N/A	0	0	Human and animal fecal waste	
Fecal Indicator (From GWR source) (coliphage, enterococci and/or E. coli)	N	0	N/A	0	0	Human and animal fecal waste	
<p><sup>1</sup> <b>Total organic carbon (TOC)</b> has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THM) and haloacetic acids (HAA). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver, or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.</p> <p><sup>2</sup> <b>Turbidity</b> is a measure of the cloudiness of water and is an indication of the effectiveness of our filtration system. We monitor it because it is a good indicator of the quality of water. High turbidity can hinder the effectiveness of disinfectants. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.</p>							
Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N	0.56 ppm	0.00 – 1.24	4	0	12/2020	Water additive used to control microbes
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	N	ND	ND	60	N/A	08/2020	Byproduct of drinking water disinfection

<b>Total Trihalomethanes (TTHM) (ppb)</b>	N	ND	ND	80	N/A	08/2020	Byproduct of drinking water disinfection
<b>Lead &amp; Copper</b>	<b>MCL Violation Y or N</b>	<b>90<sup>th</sup> Percentile</b>	<b>Number of Samples Exceeds AL</b>	<b>AL</b>	<b>ALG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
<b>Copper (ppm)</b>	N	0.014 ppm	0	1.3	1.3	08/2020	Corrosion of household plumbing systems; erosion of natural deposits
<b>Lead (ppb)</b>	N	0.00 ppb	0	15	0	08/2020	Corrosion of household plumbing systems; erosion of natural deposits
<b>Inorganic Chemicals (IOC)</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
<b>Arsenic<sup>1</sup> (ppb)</b>	Y	10.65 ppb	7.60 – 13.00	10	0	01/2020 04/2020 08/2020 10/2020	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
<b>Barium (ppm)</b>	N	0.06 ppm	0.06	2	2	04/2020	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
<b>Chromium (ppb)</b>	N	6.80 ppb	6.80	100	100	04/2020	Discharge of steel and pulp mills; Erosion of natural deposits
<b>Fluoride (ppm)</b>	N	0.43 ppm	0.43	4	4	04/2020	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
<b>Nitrate<sup>2</sup> (ppm)</b>	N	4.50 ppm	2.80 – 9.20	10	10	01/2020 04/2020 08/2020 10/2020	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Selenium (ppb)</b>	N	5.20 ppb	5.20	50	50	04/2020	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge for mines
<b>Sodium (ppm)</b>	N	77 ppm	77	N/A	N/A	04/2020	Erosion of natural deposits

<sup>1</sup> **Arsenic** is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water, and continues to research the health effects of low levels of arsenic.

<sup>2</sup> **Nitrate** in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

#### Violation Summary (for MCL, MRDL, AL, TT, or Monitoring & Reporting Requirement)

Violation Type	Explanation, Health Effects	Time Period	Corrective Actions
Arsenic MCL	Arsenic exceeded MCL limit in 4Q2020	3 months	System currently uses a blending plan to maintain arsenic levels; compliance was achieved April 2021 when ADEQ distributed a Notice of Violation closure letter.
Missed Monitoring	System failed to monitor for E Coli in February 2020	30 days	System was returned to compliance when March 2020 samples were received
Missed Monitoring	System failed to monitor for E Coli in November 2020	30 days	System was returned to compliance when December 2020 samples were received

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.