

ORIGINAL

WATER TARIFF SCHEDULE

UTILITY: Vernon Valley Water, Inc.
DOCKET NO: W-20540A-16-0333

DECISION NO: 75981
EFFECTIVE: March 1, 2017

RATES AND CHARGES

MONTHLY USAGE CHARGE:

5/8" x 3/4" Meter	\$44.75
3/4" Meter	67.13
1" Meter	111.88
1 1/2" Meter	223.75
2" Meter	358.00
3" Meter	716.00
4" Meter	1,118.75
6" Meter	2,237.50

COMMODITY RATES:

(Per 1,000 gallons)

Gallons Included in Minimum	-0-
5/8" x 3/4" and 3/4" Residential	
First 3,000 Gallons	\$5.58
From 3,001 to 9,000 Gallons	7.98
Over 9,000 Gallons	10.75
3/4" Commercial & Industrial	
First 12,500 Gallons	\$7.98
Over 12,500 Gallons	10.75
1" – Residential, Commercial & Industrial	
First 15,000 Gallons	\$7.98
Over 15,000 Gallons	10.75
1 1/2" – Residential, Commercial & Industrial	
First 25,000 Gallons	\$7.98
Over 25,000 Gallons	10.75

APPROVED FOR FILING

DECISION #: 75981

WATER TARIFF SCHEDULE

UTILITY: Vernon Valley Water, Inc.
DOCKET NO: W-20540A-16-0333

DECISION NO: 75981
EFFECTIVE: March 1, 2017

2" – Residential, Commercial & Industrial

First 40,000 Gallons	\$7.98
Over 40,000 Gallons	10.75

3" – Residential, Commercial & Industrial

First 80,000 Gallons	\$7.98
Over 80,000 Gallons	10.75

4" – Residential, Commercial & Industrial

First 125,000 Gallons	\$7.98
Over 125,000 Gallons	10.75

6" – Residential, Commercial & Industrial

First 250,000 Gallons	\$7.98
Over 250,000 Gallons	10.75

(Standpipe) Fire Hydrant

Per 1,000 Gallons	\$10.75
-------------------	---------

SERVICE LINE AND METER INSTALLATION CHARGES:

(Refundable pursuant to A.A.C. R14-2-405)

	<u>Service</u> <u>Line</u>	<u>Meter</u> <u>Charge</u>	<u>Total</u> <u>Charge</u>
5/8" x 3/4" Meter	\$0.00	\$0.00	\$0.00
3/4" Meter	230.00	90.00	320.00
1" Meter	230.00	140.00	370.00
1 1/2" Meter	280.00	265.00	545.00
2" Turbine Meter	330.00	420.00	750.00
2" Compound Meter	330.00	420.00	750.00
3" Turbine Meter	380.00	600.00	980.00
3" Compound Meter	380.00	600.00	980.00
4" Turbine Meter	650.00	1,170.00	1,820.00
4" Compound Meter	650.00	1,170.00	1,820.00
6" Turbine Meter	1,200.00	2,720.00	3,920.00
6" Compound Meter	1,200.00	2,720.00	3,920.00

APPROVED FOR FILING

DECISION #: 75981

WATER TARIFF SCHEDULE

UTILITY: Vernon Valley Water, Inc.
DOCKET NO: W-20540A-16-0333

DECISION NO: 75981
EFFECTIVE: March 1, 2017

SERVICE CHARGES:

Establishment	\$25.00
Establishment (After Hours)	N/A
After Hours Service Charge	40.00
Reconnection (Delinquent)	25.00
Reconnection (Delinquent) After Hours	N/A
Meter Test (If Correct)	25.00
Deposit	*
Deposit Interest	**
Re-Establishment (Within 12 Months)	***
NSF Check	25.00
Deferred Payment (Per Month)	****
Meter Re-read (If Correct)	15.00
Late Fee (Per Month)	*****

- * Per Commission Rule A.A.C. R14-2-403(B)(7).
- ** Per Commission Rule A.A.C. R14-2-403(B)(3).
- *** Number of months off system times the monthly minimum A.A.C. R14-2-403(D)
- **** 1.50% of unpaid monthly balance.
- ***** 1.50% or \$5.00, whichever is greater

In addition to collecting its regular rates and charges, the Company shall collect from its customers a proportionate share of any privilege, sales, or use tax per A.A.C. R14-2-409D(5).

APPROVED FOR FILING
DECISION #: 75981

CROSS-CONNECTION OR BACKFLOW TARIFF

ORIGINAL

PURPOSE:

The purpose of this tariff is to protect Vernon Valley Water, Inc. ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY****

Effective Date: 4.30.10

**ADMINISTRATIVELY
APPROVED FOR FILING**

- 5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
- 6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
- 7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
- 8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

****FOR OFFICIAL USE ONLY****

**ADMINISTRATIVELY
APPROVED FOR FILING**

Effective Date: 4.30.10

ORIGINAL

Company Name: Vernon Valley Water, Inc. Page 1 of 2

CROSS-CONNECTION OR BACKFLOW TARIFF

PURPOSE:

The purpose of this tariff is to protect Vernon Valley Water, Inc. ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY****

Effective Date: 12/18/09

ADMINISTRATIVELY
APPROVED FOR FILING

ORIGINAL

Company Name: Vernon Valley Water, Inc. Page 2 of 2

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

****FOR OFFICIAL USE ONLY****

Effective Date: 12/18/09

ADMINISTRATIVELY
APPROVED FOR FILING

ORIGINAL

TARIFF SCHEDULE

Utility: Serviceberry Water Company
Docket No.: W-2481A-04-0537
Phone No.: _____

Tariff Sheet No.: 1 of 4
Decision No.: N/A
Effective: 8.25.04

CURTAILMENT PLAN FOR Serviceberry Water
(Template 063004)

ADEQ Public Water System No: 01054

Serviceberry ("Company"), is authorized to curtail water service to all customers within its certificated area under the terms and conditions listed in this tariff.

This curtailment plan shall become part of the Arizona Department of Environmental Quality Emergency Operations Plan for the Company.

The Company shall notify its customers of this new tariff as part of its next regularly scheduled billing after the effective date of the tariff or no later than sixty (60) days after the effective date of the tariff.

The Company shall provide a copy of the curtailment tariff to any customer, upon request.

Stage 1 Exists When:

Company is able to maintain water storage in the system at 100 percent of capacity and there are no known problems with its well production or water storage in the system.

Restrictions: Under Stage 1, Company is deemed to be operating normally and no curtailment is necessary.

Notice Requirements: Under Stage 1, no notice is necessary.

Stage 2 Exists When:

- a. Company's water storage or well production has been less than 80 percent of capacity for at least 48 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 2, the Company may request the customers to voluntarily employ water conservation measures to reduce water consumption by approximately 50 percent. Outside watering should be limited to essential water, dividing outside watering on some uniform basis (such as even and odd days) and eliminating outside watering on weekends and holidays.

ADMINISTRATIVELY
APPROVED FOR FILE

ORIGINAL

TARIFF SCHEDULE

Utility: Serviceberry Water Company
Docket No.: W-02481A-04-0537
Phone No.: _____

Tariff Sheet No.: 2 of 4
Decision No.: N/A
Effective: 8.25.04

Notice Requirements: Under Stage 2, the Company is required to notify customers by delivering written notice door to door at each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.

Stage 3 Exists When:

- a. Company's total water storage or well production has been less than 50 percent of capacity for at least 24 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 3, Company shall request the customers to voluntarily employ water conservation measures to reduce daily consumption by approximately 50 percent. All outside watering should be eliminated, except livestock, and indoor water conservation techniques should be employed whenever possible. Standpipe service shall be suspended.

Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such Notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Beginning with Stage 3, Company shall post at least 1 signs showing the curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to major subdivisions served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 3.

Once Stage 3 has been reached, the Company must begin to augment the supply of water by either hauling or through an emergency interconnect with an approved water supply in an attempt to maintain the curtailment at a level no higher than Stage 3 until a permanent solution has been implemented.

ADMINISTRATIVELY
APPROVED FOR FILING

REVISED: June 30, 2004

TARIFF SCHEDULE

Utility: Serviceberry Water Company Tariff Sheet No.: 3 of 4
 Docket No.: W-02481A-04-0537 Decision No.: N/A
 Phone No.: _____ Effective: 8-25-04

Stage 4 Exists When:

- a. Company's total water storage or well production has been less than 25 percent of capacity for at least 12 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 4, Company shall inform the customers of a **mandatory** restriction to employ water conservation measures to reduce daily consumption. Failure to comply will result in customer disconnection. The following uses of water shall be prohibited:

- ◆ Irrigation of outdoor lawns, trees, shrubs, or any plant life is prohibited
- ◆ Washing of any vehicle is prohibited
- ◆ The use of water for dust control or any outdoor cleaning uses is prohibited
- ◆ The use of drip or misting systems of any kind is prohibited
- ◆ The filling of any swimming pool, spas, fountains or ornamental pools is prohibited
- ◆ The use of construction water is prohibited
- ◆ Restaurant patrons shall be served water only upon request
- ◆ Any other water intensive activity is prohibited

The Company's operation of its standpipe service is prohibited. The addition of new service lines and meter installations is prohibited.

Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Company shall post at least 1 signs showing curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to major subdivisions served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 4.

ADMINISTRATIVELY
APPROVED FOR FILING

ORIGINAL

TARIFF SCHEDULE

Utility: Serviceberry Water Company
Docket No.: W-024914-04-0537
Phone No.: _____

Tariff Sheet No.: 4 of 4
Decision No.: N/A
Effective: 8.25.04

Customers who fail to comply with the above restrictions will be given a written notice to end all outdoor use. Failure to comply within two (2) working days of receipt of the notice will result in temporary loss of service until an agreement can be made to end unauthorized use of outdoor water. To restore service, the customer shall be required to pay all authorized reconnection fees. If a customer believes he/she has been disconnected in error, the customer may contact the Commission's Consumer Services Section at 1-800-222-7000 to initiate an investigation.

Once Stage 4 has been reached, the Company must augment the supply of water by hauling or through an emergency interconnect from an approved supply or must otherwise provide emergency drinking water for its customers until a permanent solution has been implemented.

ADMINISTRATIVELY
APPROVED FOR FILING